

NOTES

- 1. * INDICATES COMPONENTS NOT SUPPLIED BY MANUFACTURER.
- 2. REFER TO THE INSTALLATION AND OPERATION MANUAL FOR DRIVE FUNCTIONS AND PARAMETER SETTINGS.
- 3. FEEDER CIRCUIT PROTECTION, INPUT POWER AND MOTOR WIRING MUST BE SELECTED IN ACCORDANCE WITH THE N.E.C., ANY APPLICATION LOCAL CODES AND THE LOAD CURRENT RATING.
- 4. REPLACE JUMPER 'J1' WITH NORMALLY CLOSED SAFETY INTERLOCK CONTACT AS NECESSARY. CONTACT MUST BE RATED 1/4 HP @ 120VAC MINIMUM.
- 5. PANEL MAY REQUIRE DERATING, CONSULT DRIVE MANUAL OR FACTORY FOR FOLLOWING CONDITIONS:
- 5.1. HIGHER SWITCHING FREQUENCY THEN DRIVE DEFAULT
- 5.2. HIGHER THEN PANEL LISTED AMBIENT TEMPERATURES
- 5.3. ELEVATION ABOVE 3300 FEET (1000 METERS)
- 5.4. LONG MOTOR LEAD LENGTHS
- 6. WHEN MOTOR OVERLOADS SIZES ARE DIFFERENT, MOTOR 1 WILL BE THE LARGER OF THE TWO MOTORS

WARNING!
THE FOLLOWING TABLE LIST THE PARAMETERS THAT ARE SET DIFFERENT FROM THE DRIVE DEFAULT SETTINGS.

SET DIFFERENT FROM THE DRIVE DEFAULT SETTINGS.
ADDITIONAL PARAMETER SETTINGS MAY BE REQUIRED
FOR YOUR APPLICATION.

DRIVE PARAMETER SETTINGS

PARAMETER #	NAME	SETTING	VALUE
0-02	MOTOR SPEED UNIT	1	HZ
0-03	REGIONAL SETTINGS	1	NORTH AMERICA
1-03	TORQUE CHAR.	1	VARIABLE TORQUE
5-02	TERMINAL 29 TYPE	1	OUTPUT
5-31	TERMINAL 29	5	RUNNING
14-20	RESET MODE	13	INFINITE AUTO REST

В			-NOTICE-	DRN	NAME		EMA 3R,240V,2C	THE TRANE COMPANY
Α			THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF THE TRANE COMPANY	DTM			AIN CB,DRIVE FUSE IR,DUAL MOTOR,1 FAN	A DIVISION OF AMERICAN STANDARD INC.
DR	ECNSP09001	1/09		APR	MODEL	,JMD1,	· · · · · · · · · · · · · · · · · · ·	7.4.1.7.0.0.0
REV	ECN	DATE		DTM	MODEL	VLT	PAGE $\underline{1}$ OF $\underline{2}$ SIZE A NO. 1 $\overline{7}$	4N3926



TERMINAL IDENTIFICATION

X - DRIVE TREMINAL


O - CUSTOMER TERMINAL


CUSTOMER DRY CONTACT RATINGS

RELAY	CONTACT RATING	
CR1, CR6	5A @ 120VAC 1/10 HP @ 120VAC	
M2, M3	10A @ 120/240VAC	



X INDICATES CONTACT CLOSED					
POSITION					
CONTACT	DRIVE	OFF	BYPASS		
13-14			Χ		
23-24	Χ				





В		
Α		
DR	ECNSP09001	1/09
REV	ECN	DATE

-NOTICE-THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF THE TRANE COMPANY

	DTM	NAME	,MA	EMA 3R,240V,2C IN CB,DRIVE FUSE	A N I
APR		i	JMB1,1	R,DUAL MOTOR,1 F	ΑN
	DTM	MODEL	VLT	PAGE 2 OF 2 SIZ	ΈΔ

THE TRANE COMPANY A DIVISION OF AMERICAN STANDARD INC.