

B				DRN	NAME				NEMA 3R,480V,3C		
A				DTM					,MAIN CB,DRIVE FUSE		
				APR					,3MB2,IR,SINGLE MOTOR,1 FAN		
REV	ECN	DATE		DTM	MODEL	VLT	PAGE 1 OF 2	SIZE A	DWG NO. 174N4201		





TERMINAL IDENTIFICATION

<input checked="" type="checkbox"/>	- DRIVE TERMINAL
<input checked="" type="checkbox"/>	- CUSTOMER TERMINAL

POSITION CONTACT	DRIVE	OFF	BYPASS	TEST
1-2	X			X
3-4			X	X
5-6	X			
7-8				X

CUSTOMER DRY CONTACT RATINGS

RELAY	CONTACT RATING
CR6	5A • 120VAC 1/10 HP • 120VAC
M1, M2, M3	10A • 120/240VAC



B			<p align="center">-NOTICE-</p> <p>THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF THE TRANE COMPANY</p>	DRN	NAME				THE TRANE COMPANY	
A				DTM	NEMA 3R,480V,3C MAIN CB,DRIVE FUSE 3MB2,IR,SINGLE MOTOR,1 FAN				A DIVISION OF AMERICAN STANDARD INC.	
DR	ECNSP09001	1/09		APR	MODEL		PAGE 2 OF 2	SIZE A	DWG NO. 174N4201	
REV	ECN	DATE		DTM	VLT					