

| | | |
|-------------------|--|----------------|
| Introduction Note | Trane® TR200 Service Release MKII firmware 4.0) bck V&a dUjV Y k jH Danfoss BACnet/IP MCA-125 option. | Week 4 2024 |
|-------------------|--|----------------|

Please use only the information available in the sections "New features/Additions" and "Changes/Improvements"

Concerning: BACnet/IP Service Release control card firmware for TR200 SXXX

General information:

We are pleased to announce the Service Release of P5050 (MKII) SW to now include BACnet/IP on TR-200 drives. This will not be a production release as Trane factories would have to assign resources to validate Danfoss released SW. This is only a field installable SW for any needed BACnet IP applications. Danfoss 134B1586 MCA-125 BACnet/IP options were updated Week 40 2023 with SW 3.02 which will allow Trane TR-200 SXXX typecodes.

* BACnet/IP Option cards will have to be ordered as a separate line item in addition to the TR-200 drive. This is not a Danfoss factory installable option.

Installation information:

TR-200 Control Card SW 4.05 will be available on TraneDrives.com and has to be installed (via MCT-10) before the option card is physically installed on the TR-200 drive.

Latest spare part ordering numbers for P5050 MKII cards:

| | |
|--|----------------------|
| Control Card with safe stop for TR-200 | 134B7043 or 134B7044 |
| Control Card w/o safe stop for TR-200 | 134B7045 or 134B7046 |

- Service Release 23.64 SW lets control card work with updated MCA-125 option
- New MCA-125 Option SW 3.02 prevents TR-200's from getting "Illegal Option Detected" alarm.

Responsible Product Manager:

Hector Flores
Trane Product Manager
TRANE® TR-200
Tel: 815-639-8828
Mobile: 815-394-9709
HFlores@danfoss.com



Checked by: RL